"Copyright © 2023/2024/2025/2026 International Code Council, Inc. All rights reserved."

Item 5 IMC Plant processing and extraction facility ventilation. See M27-21

Section 408.2 needs to revised or removed?

Work Group #3 established: Andrew Bevis-Chair, Kevin Brenton-Vice Chair

M17-21 was:

Add new text as follows:

SECTION 408 PROCESSING AND EXTRACTION FACILITIES.

408.1 General. Plant processing or extraction facilities shall comply with this section, the International Building Code and Chapter 39 of the International Fire Code. The extraction process includes the act of extraction of the oils and fats by use of a solvent, desolventizing of the raw material, production of the miscella, distillation of the solvent from the miscella and solvent recovery. Post-extraction processing includes winterization, solvent recovery, distillation, decarboxylation, isolation, chromatography and similar processes. The use, storage, transfilling and handling of hazardous materials in these facilities shall comply with this code, the International Building Code and the International Fire Code.

408.2 Existing buildings or facilities. Existing buildings or facilities used for the processing of plants shall comply with this code, the International Building Code and the International Fire Code. Existing extraction processes where the medium of extraction or solvent is changed shall comply with this section.

408.3 Mechanical ventilation. Natural ventilation shall not be permitted. Mechanical ventilation shall be designed and installed in accordance with Section 403 t3T 12 -0 0 12 36 414.xT 12 -0 0 12 35(u)56(gn)1(

“Copyright © 2023/2024/2025/2026 International Code Council, Inc. All rights reserved.”

Item 7 IMC Table 403.3.1.1 – category description needs clarity

“Copyright © 2023/2024/2025/2026 International Code Council, Inc. All rights reserved.”

hourly rainfall rate indicated in Figures 1106.1(1) through 1106.1(5) or on other rainfall rates determined from approved local weather data.

From the IBC :

1611.1 Design rain loads. Each portion of a roof shall be designed to sustain the load of rainwater as per the requirements of Chapter 8 of ASCE 7. The design rainfall shall be based on the 100-year 15-minute duration event, or on other rainfall rates determined from approved local weather data. Alternatively, a design rainfall of twice the 100-year hourly rainfall rate indicated in Figures 1611.1(1) through 1611.1(5) shall be p 0 Td ( )Td ( )Tj grovent,o 10.2 36 57902 TwT8301-1(1)1m [(1289 /C-

“Copyright © 2023/2024/2025/2026 International Code Council, Inc. All rights reserved.”

Item 9a IMC Roof hatch size not defined for hatches that don’t have stairways Ref IBC 1011.12.2

From the IMC

306.5 Equipment and appliances on roofs or elevated structures.

CDP

Where equipment requiring access or appliances are located on an elevated structure or the roof of a building such that personnel will have to climb higher than 16 feet (4877 mm) above grade to access such equipment or appliances, an interior or exterior means of access shall be provided. Such access shall not require climbing over obstructions greater than 30 inches (762 mm) in height or walking on roofs having a slope greater than 4 units vertical in 12 units horizontal (33-percent slope). Such access shall not require the use of portable ladders. Where access involves climbing over parapet walls, the height shall be measured to the top of the parapet wall.

Permanent ladders installed to provide the required access shall comply with the following minimum design criteria:

1. The side railing shall extend above the parapet or roof edge not less than 30 inches (762 mm).
2. Ladders shall have rung spacing not to exceed 14 inches (356 mm) on center. The uppermost rung shall be not greater than 24 inches (610 mm) below the upper edge of the roof hatch, roof or parapet, as applicable.
3. Ladders shall have a toe spacing not less than 6 inches (152 mm) deep.
4. There shall be not less than 18 inches (457 mm) between rails.
5. Rungs shall have a diameter not less than 0.75-inch (19.1 mm) and be capable of withstanding a 300-pound (136 kg) load.
6. Ladders over 30 feet (9144 mm) in height shall be provided with offset sections and landings

"Copyright © 2023/2024/2025/2026 International Code Council, Inc. All rights reserved."

Exception: This section shall not apply to Group R-3 occupancies.

From the IBC

1011.12.2 Roof access. Where a stairway is provided to a roof, access to the roof shall be provided through a penthouse complying with Section 1511.2.

> Exception: In buildings without an occupied roof, access to the roof shall be permitted to be a roof hatch or trap door not less than 16 square feet (1.5 m^2) in area and having a minimum dimension of 2 feet (610 mm).

Item 10 ISPSC Shallow water depth of 33 inches and sun shelfs AND 4 foot depth max.

From the ISPSC:

807.2 Shallow end water depths.

“Copyright © 2023/2024/2025/2026 International Code Council, Inc. All rights reserved.”

"Copyright © 2023/2024/2025/2026 International Code Council, Inc. All rights reserved."

Item 14 IPC Cleanup errors in Table E103.3(1)

The reported errors are:

1. Row E states "Static Head Loss 21 x 43 psi"

a. Following unit convention from the above rows, 21 should read as (21').

b. The conversion from feet to psi is .43 psi.

2. The addition of cold water friction loss does not equal what is presented in row K

a. 2.21 + .38 + .38 + 3.08 = 6.05. The table states 5.93 as the total, which is correct, but not based off the table. The length of BC + equivalent fittings length is = 20 when it should be 15 (sum of 8+7).

This is leading to error in summing the total friction losses.

From the IPC:

TABLE E103.3(1)
RECOMMENDED TABULAR ARRANGEMENT FOR USE IN SOLVING PIPE SIZING PROBLEMS

COLUMN	1	2	3	4	5	6	7	8	9	10

“Copyright © 2023/2024/2025/2026 International Code Council, Inc. All rights reserved.”

B		Highest pressure required at a fixture (Table 604.3)	15.00								
C		Meter O R V V meter	11.0 < 0								
D		Tap in main loss < W D S [Table E103.3(4)]	1.61								
E		Static head loss 21 × 43 psi	9.03								
F		Special fixture loss backflow preventer	9.00								
G		Special fixture loss—Filter	0.00								
H		Special fixture loss—Other	0.00								

“Copyright © 2023/2024/2025/2026 International Code Council, Inc. All rights reserved.”

I		Total overall losses and requirements (Sum of Lines B through H)	45.64								

Pressure
avaiT1 1 T-8Cv45.6c.002 Twd ( )Tj ET.2(v)-5.3(a)-2t(s)-80.9(n)-550.68 57.12 134.6382651/P <</0M

J

"Copyright © 2023/2024/2025/2026 International Code Council, Inc. All rights reserved."

From the IPC:

TABLE E103.3(3)
TABLE FOR ESTIMATING DEMAND

SUPPLY SYSTEMS PREDOMINANTLY FOR FLUSH TANKS			SUPPLY SYSTEMS PREDOMINANTLY FOR FLUSHOMETER VALVES		
Load	Demand		Load	Demand	
(Water supply fixture units)	(Gallons per minute)	(Cubic feet per minute)	(Water supply fixture units)	(Gallons per minute)	(Cubic feet per minute)
1	3.0	0.04104	—	—	—
2	5.0	0.0684			

Item 16 IPC Point of use hot water recirculation pumps for commercial buildings

This is what was relayed by Ron George in the meeting chat:

Remove Code language allowing HW recirc in CW piping for multi-tenant buildings. (Single Family Owner occupied Residential only- Not public Rental Property)

Staff remark: Is Section 607.2.1.2 the section that is involved?

From the IPC:

607.2.1.2 Demand recirculation controls for distribution systems. A water distribution system having one or more recirculation pumps that pump water from a heated water supply pipe back to the heated water source through a cold water supply pipe shall be a demand recirculation water system. Pumps shall have controls that comply with both of the following:

1. The control shall start the pump upon receiving a signal from the action of a user of a fixture or appliance, sensing the presence of a user of a fixture, or sensing the flow of hot or tempered water to a fixture fitting or appliance.
2. The control shall limit the temperature of the water entering the cold water piping to 104°F (40°C).

"Copyright © 2023/2024/2025/2026 International Code Council, Inc. All rights reserved."

403.1.1 Fixture calculations. To determine the occupant load of each sex, the total occupant load shall be divided in half. To determine the required number of fixtures, the fixture ratio or ratios for each fixture type shall be applied to the occupant load of each sex in accordance with Table 403.1. Fractional numbers resulting from applying the fixture ratios of Table 403.1 shall be rounded up to the next whole number. For calculations involving multiple occupancies, such fractional numbers for each occupancy shall first be summed and then rounded up to the next whole number.

Exceptions:

1. The total occupant load shall not be required to be divided in half where approved statistical data indicate a distribution of the sexes of other than 50 percent of each sex.
2. Where multiple-user facilities are designed to serve all genders, the minimum fixture count shall be calculated 100 percent, based on total occupant load. In such multiple-user facilities, each fixture type shall be in accordance with ICC A117.1 and each urinal that is provided shall be located in a stall.
3. Distribution of the sexes is not required where single-user water closets and bathing room fixtures are provided in accordance with Section 403.1.2.

Item 20 IMC Section 402 needs revised based upon how ASHRAE 62.1-2022 deals with natural ventilation.